

# Appendix 2

## Results Tables

**93 Bollo Lane, South Acton, London**  
**Adjoining owners daylight results**  
**Job 11 15 June 2021**

Room/Floor	Room Use	Window	%VSC			% Daylight Factor			Daylight Distribution					
			Exist	Prop	% Loss	Exist	Prop	% Loss	Room Area sq ft	Existing Area sq ft	Existing % of Room Area	Proposed Area sq ft	Proposed % of Room Area	% Loss of Existing
<b>42 Weston Road BRE_05-06</b>														
<b>1st Floor</b>														
R1/11	BEDROOM	W1/11	22.28	22.19	0.40%	1.11	1.11	0.45%	70.7	64.2	90.81%	64.2	90.81%	0.00%
<b>2nd Floor</b>														
R1/12	BEDROOM	W1/12	27.70	26.93	2.78%	1.76	1.67	5.10%	254.7	249	97.76%	249	97.76%	0.00%
		W2/12	35.62	33.03	>27									
<b>Gnd Floor</b>														
R1/20	KITCHEN	W1/20	38.49	38.47	>27	6.74	6.32	6.26%	197.2	193.1	97.92%	193.1	97.92%	0.00%
		W2/20	33.25	28.97	>27									
<b>1st Floor</b>														
R1/21	BEDROOM	W1/21	34.75	31.22	>27	3.17	2.91	8.18%	62.9	61.3	97.46%	61.3	97.46%	0.00%
		W2/21	34.61	30.88	>27									
<b>44 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R1/10	BEDROOM	W1/10	17.22	13.68	20.56%	0.95	0.81	14.56%	71.1	60.1	84.53%	49.7	69.90%	17.30%
<b>1st Floor</b>														
R2/11	BEDROOM	W2/11	25.32	21.43	15.36%	1.18	1.04	11.32%	71.1	59.8	84.11%	53.9	75.81%	9.87%
<b>Gnd Floor</b>														
R2/20	UNKNOWN	W3/20	31.18	26.43	15.23%	2.13	1.87	12.46%	164.4	161.5	98.24%	151.6	92.21%	6.13%
<b>1st Floor</b>														
R2/21	BEDROOM	W3/21	34.52	30.35	>27	2.60	2.34	10.16%	86.7	84	96.89%	83.1	95.85%	1.07%
		W4/21	34.57	30.07	>27									
<b>46 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R2/10	KITCHEN	W2/10	16.69	15.94	4.49%	0.77	0.74	3.64%	99.9	90.5	90.59%	90	90.09%	0.55%
<b>1st Floor</b>														
R3/11	BEDROOM	W3/11	25.49	23.76	6.79%	1.12	1.06	5.47%	86.7	79.8	92.04%	79.3	91.46%	0.63%
<b>Gnd Floor</b>														
R5/20	LIVINGROOM	W6/20	57.79	56.76	>27	2.85	2.57	9.82%	338.1	335.7	99.29%	334.6	98.96%	0.33%
		W7/20	64.53	62.93	>27									
		W8/20	30.37	23.08	24.00%									
		W9/20	78.56	74.54	>27									
		W10/20	76.93	72.73	>27									
<b>1st Floor</b>														
R5/21	KITCHEN	W7/21	34.05	27.85	>27	1.98	1.67	15.89%	112.5	109.2	97.07%	98.9	87.91%	9.43%
		W8/21	34.02	27.55	>27									
<b>48 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R3/10	UNKNOWN	W3/10	10.55	7.41	29.76%	0.56	0.45	19.46%	118.6	72.9	61.47%	41.9	35.33%	42.52%
<b>1st Floor</b>														
R4/11	BEDROOM	W4/11	18.51	13.69	26.04%	0.90	0.71	20.56%	86.7	77	88.81%	62.9	72.55%	18.31%
<b>2nd Floor</b>														
R3/12	BEDROOM	W4/12	24.23	19.13	21.05%	2.38	2.31	2.81%	236	236	100.00%	236	100.00%	0.00%
		W27/12	84.19	84.19	>27									
		W28/12	86.27	86.27	>27									
<b>Gnd Floor</b>														
R6/20	LIVINGROOM	W11/20	27.75	20.29	26.88%	2.23	1.76	20.99%	136.9	136.3	99.56%	96	70.12%	29.57%
<b>1st Floor</b>														
R6/21	BEDROOM	W9/21	33.81	26.85	20.59%	2.22	1.81	18.36%	112.5	109.3	97.16%	94.2	83.73%	13.82%
		W10/21	33.89	26.61	21.48%									
<b>50 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R4/10	LIVINGROOM	W4/10	10.00	7.25	27.50%	1.27	1.24	1.89%	268.1	217.1	80.98%	204.1	76.13%	5.99%
		W16/10	31.18	31.18	>27									
		W17/10	31.20	31.20	>27									
<b>1st Floor</b>														
R5/11	BEDROOM	W5/11	20.65	17.04	17.48%	0.84	0.73	12.75%	115.2	91.3	79.25%	81.3	70.57%	10.95%
<b>2nd Floor</b>														
R5/12	BEDROOM	W5/12	34.46	28.92	>27	2.67	2.45	8.36%	184.7	176.3	95.45%	176.1	95.34%	0.11%
		W7/12	33.81	28.43	>27									
		W26/12	84.08	84.08	>27									

Room/Floor	Room Use	Window	%VSC			% Daylight Factor			Daylight Distribution					
			Exist	Prop	% Loss	Exist	Prop	% Loss	Room Area sq ft	Existing Area sq ft	Existing % of Room Area	Proposed Area sq ft	Proposed % of Room Area	% Loss of Existing
<b>Gnd Floor</b>														
R9/20	KD	W14/20	29.72	21.32	28.26%	1.80	1.39	22.88%	159.1	157.7	99.12%	86.4	54.31%	45.21%
<b>1st Floor</b>														
R8/21	BEDROOM	W12/21	33.49	25.40	24.16%	2.12	1.65	21.95%	112.6	109	96.80%	90.8	80.64%	16.70%
		W13/21	33.50	25.04	25.25%									
<b>52 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R5/10	KITCHEN	W5/10	10.33	7.07	31.56%	0.60	0.47	21.51%	100.1	53.8	53.75%	28.3	28.27%	47.40%
<b>1st Floor</b>														
R6/11	BEDROOM	W6/11	18.87	14.03	25.65%	0.79	0.64	18.27%	115.1	83	72.11%	47.2	41.01%	43.13%
<b>2nd Floor</b>														
R7/12	UNKNOWN	W9/12	34.12	27.68	>27	4.78	4.38	8.39%	129.8	129.8	100.00%	129.8	100.00%	0.00%
		W24/12	82.87	82.87	>27									
		W25/12	84.39	84.39	>27									
<b>Gnd Floor</b>														
R10/20	BEDROOM	W15/20	28.58	19.58	31.49%	2.32	1.74	25.09%	112.6	109.9	97.60%	71.8	63.77%	34.67%
<b>1st Floor</b>														
R9/21	BEDROOM	W14/21	33.25	24.45	26.47%	2.10	1.59	24.24%	112.6	109.3	97.07%	83.6	74.25%	23.51%
		W15/21	33.12	24.11	27.20%									
<b>54 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R6/10	UNKNOWN	W6/10	11.16	7.91	29.12%	0.58	0.47	19.10%	115.7	76.4	66.03%	45.4	39.24%	40.58%
<b>1st Floor</b>														
R7/11	BEDROOM	W7/11	23.24	18.24	21.51%	0.86	0.71	17.00%	115.7	107.1	92.57%	87.7	75.80%	18.11%
<b>2nd Floor</b>														
R8/12	UNKNOWN	W10/12	34.15	27.62	>27	2.40	2.30	4.53%	178.6	171.6	96.08%	171.6	96.08%	0.00%
		W22/12	84.28	84.28	>27									
		W23/12	82.69	82.69	>27									
<b>Gnd Floor</b>														
R13/20	UNKNOWN	W18/20	31.27	21.08	32.59%	1.02	0.72	29.38%	110.4	100.9	91.39%	56	50.72%	44.50%
<b>1st Floor</b>														
R12/21	BEDROOM	W18/21	32.81	23.04	29.78%	2.11	1.53	27.31%	110.4	108.9	98.64%	79.4	71.92%	27.09%
		W19/21	32.79	22.76	30.59%									
<b>2nd Floor</b>														
R2/22	UNKNOWN	W2/22	97.22	94.77	>27	3.47	3.08	11.25%	59.6	56.2	94.30%	56.2	94.30%	0.00%
		W3/22	34.03	25.88	23.95%									
<b>56 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R7/10	UNKNOWN	W7/10	9.97	6.56	34.20%	0.55	0.42	23.81%	115.7	67.3	58.17%	33	28.52%	50.97%
<b>1st Floor</b>														
R8/11	BEDROOM	W8/11	20.35	15.47	23.98%	0.78	0.64	18.90%	115.7	95.5	82.54%	63.7	55.06%	33.30%
<b>Gnd Floor</b>														
R14/20	UNKNOWN	W19/20	28.69	18.62	35.10%	2.91	2.12	27.23%	110.4	106.1	96.11%	63	57.07%	40.62%
<b>1st Floor</b>														
R13/21	BEDROOM	W20/21	32.62	22.28	31.70%	2.10	1.49	28.88%	110.4	108.3	98.10%	71.5	64.76%	33.98%
		W21/21	32.60	22.11	32.18%									
<b>58 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R8/10	BEDROOM	W8/10	11.02	7.44	32.49%	0.62	0.48	22.10%	101.9	63.5	62.32%	42.2	41.41%	33.54%
<b>1st Floor</b>														
R9/11	BEDROOM	W9/11	22.84	16.57	27.45%	0.86	0.68	21.53%	115.7	107.6	93.00%	74.9	64.74%	30.39%
<b>Gnd Floor</b>														
R17/20	LKD	W22/20	17.64	16.05	9.01%	9.03	7.91	12.50%	255.2	242.4	94.98%	150.2	58.86%	38.04%
		W23/20	73.48	65.24	>27									
		W24/20	27.87	16.39	41.19%									
<b>1st Floor</b>														
R16/21	BEDROOM	W25/21	32.17	21.30	33.79%	2.35	1.65	29.85%	111.9	110	98.30%	71.8	64.16%	34.73%
		W26/21	32.30	21.43	33.65%									
<b>60 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R9/10	UNKNOWN	W9/10	9.04	5.77	36.17%	0.52	0.39	25.24%	115.7	62.2	53.76%	27.5	23.77%	55.79%
<b>1st Floor</b>														
R10/11	BEDROOM	W10/11	18.69	14.12	24.45%	0.76	0.62	18.65%	115.7	91.2	78.82%	62.9	54.36%	31.03%
<b>2nd Floor</b>														
R9/12	KITCHEN	W11/12	33.52	25.68	23.39%	1.72	1.37	20.38%	127.7	119.7	93.74%	115.4	90.37%	3.59%
<b>Gnd Floor</b>														
R18/20	LIVINGROOM	W25/20	26.82	16.53	38.37%	1.81	1.24	31.73%	160.2	155.7	97.19%	50	31.21%	67.89%
<b>1st Floor</b>														
R17/21	BEDROOM	W27/21	32.02	21.04	34.29%	2.65	1.84	30.56%	92.4	91	98.48%	72.6	78.57%	20.22%
		W28/21	32.00	20.92	34.63%									

Room/Floor	Room Use	Window	%VSC			% Daylight Factor			Daylight Distribution					
			Exist	Prop	% Loss	Exist	Prop	% Loss	Room Area sq ft	Existing Area sq ft	Existing % of Room Area	Proposed Area sq ft	Proposed % of Room Area	% Loss of Existing
<b>62 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R10/10	UNKNOWN	W10/10	10.32	6.55	36.53%	0.57	0.42	26.01%	114.2	73.9	64.71%	34.1	29.86%	53.86%
<b>1st Floor</b>														
R11/11	BEDROOM	W11/11	21.36	14.51	32.07%	0.82	0.61	25.18%	115.7	107.1	92.57%	66.4	57.39%	38.00%
<b>2nd Floor</b>														
R10/12	KD	W12/12	33.06	24.90	24.68%	2.30	1.94	15.46%	131	131	100.00%	128.1	97.79%	2.21%
		W21/12	82.41	82.41	>27									
<b>Gnd Floor</b>														
R20/20	LIVINGROOM	W27/20	27.28	16.85	38.23%	2.14	1.47	31.42%	237.6	232.5	97.85%	92.2	38.80%	60.34%
<b>1st Floor</b>														
R20/21	BEDROOM	W31/21	31.68	20.51	35.26%	2.14	1.47	31.23%	124.5	122.3	98.23%	72.8	58.47%	40.47%
		W32/21	31.55	20.42	35.28%									
<b>64 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R11/10	LIVINGROOM	W11/10	6.44	3.88	39.75%	1.35	1.29	4.38%	259.8	201.3	77.48%	185.5	71.40%	7.85%
		W14/10	31.06	31.06	>27									
		W15/10	31.07	31.07	>27									
<b>1st Floor</b>														
R12/11	BEDROOM	W12/11	8.85	5.79	34.58%	0.50	0.38	23.60%	111.1	48.6	43.74%	31.2	28.08%	35.80%
<b>2nd Floor</b>														
R11/12	UNKNOWN	W13/12	32.58	23.15	28.94%	3.41	3.01	11.78%	95.4	94.7	99.27%	94.7	99.27%	0.00%
		W14/12	97.97	94.80	>27									
R12/12	BEDROOM	W15/12	16.94	13.45	20.60%	1.10	1.02	7.43%	161.1	159.3	98.88%	159.3	98.88%	0.00%
		W20/12	82.57	82.57	>27									
<b>Gnd Floor</b>														
R21/20	KITCHEN	W28/20	27.20	17.31	36.36%	2.60	1.92	26.17%	166.7	162.3	97.36%	83	49.79%	48.86%
		W29/20	3.64	3.37	7.42%									
<b>1st Floor</b>														
R21/21	BEDROOM	W33/21	31.43	20.33	35.32%	2.17	1.49	31.20%	121.5	117.5	96.71%	74.9	61.65%	36.26%
		W34/21	31.45	20.33	35.36%									
<b>66 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R12/10	LIVINGROOM	W12/10	5.84	4.16	28.77%	0.46	0.32	29.17%	110.1	55.7	50.59%	22.3	20.25%	59.96%
<b>1st Floor</b>														
R13/11	BEDROOM	W13/11	11.87	6.08	48.78%	0.60	0.39	34.56%	110.1	71.2	64.67%	31.3	28.43%	56.04%
<b>2nd Floor</b>														
R13/12	BEDROOM	W16/12	20.01	13.32	33.43%	1.16	1.01	13.25%	155.1	155.1	100.00%	153.7	99.10%	0.90%
		W19/12	80.99	80.99	>27									
R14/12	BEDROOM	W17/12	31.34	28.22	>27	5.45	4.32	20.74%	128.9	128.9	100.00%	124.7	96.74%	3.26%
		W18/12	32.50	22.73	30.06%									
<b>Gnd Floor</b>														
R23/20	KITCHEN	W31/20	25.31	16.95	33.03%	1.92	1.38	27.99%	239.1	238	99.54%	118.6	49.60%	50.17%
		W32/20	28.53	18.09	36.59%									
<b>1st Floor</b>														
R24/21	BEDROOM	W38/21	31.16	20.26	34.98%	2.20	1.53	30.74%	117.2	114.4	97.61%	78.3	66.81%	31.56%
		W39/21	31.02	20.24	34.75%									
<b>68 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R13/10	UNKNOWN	W13/10	7.51	6.22	17.18%	0.46	0.41	11.28%	115.7	55.7	48.14%	35.2	30.42%	36.80%
<b>1st Floor</b>														
R14/11	BEDROOM	W14/11	18.98	15.54	18.12%	0.77	0.66	14.01%	115.7	90.9	78.57%	72.4	62.58%	20.35%
<b>Gnd Floor</b>														
R24/20	UNKNOWN	W33/20	26.63	17.70	33.53%	2.87	2.11	26.46%	112.4	109.2	97.15%	72	64.06%	34.07%
<b>1st Floor</b>														
R25/21	BEDROOM	W40/21	30.88	20.33	34.16%	2.25	1.58	29.86%	112.4	108.9	96.89%	75.3	66.99%	30.85%
		W41/21	30.84	20.36	33.98%									
<b>70 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R1/50	BEDROOM	W1/50	10.86	6.47	40.42%	0.69	0.49	28.28%	102.8	76.7	74.61%	33.8	32.88%	55.93%
<b>1st Floor</b>														
R1/51	BEDROOM	W1/51	22.39	14.29	36.18%	1.04	0.75	27.60%	102.8	94.6	92.02%	56.8	55.25%	39.96%
<b>2nd Floor</b>														
R1/52	UNKNOWN	W1/52	32.42	24.39	24.77%	1.96	1.54	21.41%	136.9	132.8	97.01%	88.8	64.86%	33.13%
		W2/52	32.21	24.32	24.50%									
<b>Gnd Floor</b>														
R2/60	LKD	W2/60	27.97	17.94	35.86%	0.99	0.69	30.07%	197.7	153.8	77.79%	48.5	24.53%	68.47%
<b>1st Floor</b>														
R2/61	BEDROOM	W2/61	30.42	20.32	33.20%	2.10	1.51	28.31%	122.2	118.6	97.05%	72.8	59.57%	38.62%
		W3/61	29.40	19.40	34.01%									

Room/Floor	Room Use	Window	%VSC			% Daylight Factor			Daylight Distribution					
			Exist	Prop	% Loss	Exist	Prop	% Loss	Room Area sq ft	Existing Area sq ft	Existing % of Room Area	Proposed Area sq ft	Proposed % of Room Area	% Loss of Existing
<b>72 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R2/50	LIVINGROOM	W2/50	6.71	6.16	8.20%	1.50	1.48	1.13%	261.2	260.6	99.77%	260.6	99.77%	0.00%
		W4/50	32.88	32.88	>27									
		W5/50	32.89	32.89	>27									
<b>1st Floor</b>														
R2/51	BEDROOM	W2/51	10.18	8.51	16.40%	0.66	0.59	10.41%	98.8	65.1	65.89%	65.1	65.89%	0.00%
<b>2nd Floor</b>														
R2/52	BEDROOM	W3/52	24.61	20.41	17.07%	1.42	1.35	4.86%	145.9	137.4	94.17%	137.4	94.17%	0.00%
		W6/52	80.47	80.47	>27									
<b>Gnd Floor</b>														
R3/60	KITCHEN	W3/60	24.10	16.36	32.12%	1.94	1.47	24.21%	172.7	157.7	91.31%	66.5	38.51%	57.83%
		W4/60	3.35	3.35	0.00%									
<b>1st Floor</b>														
R3/61	BEDROOM	W4/61	30.62	20.69	32.43%	2.09	1.51	27.53%	124.2	120.9	97.34%	83.4	67.15%	31.02%
		W5/61	30.42	20.67	32.05%									
<b>2nd Floor</b>														
R1/62	BEDROOM	W1/62	32.07	23.10	27.97%	3.08	2.37	23.11%	88.3	80.3	90.94%	75.6	85.62%	5.85%
		W2/62	16.17	16.17	0.00%									
<b>74 Weston Road BRE_05-06</b>														
<b>Gnd Floor</b>														
R3/50	UNKNOWN	W3/50	9.17	5.93	35.33%	0.61	0.47	23.53%	106.8	76.2	71.35%	52.4	49.06%	31.23%
<b>1st Floor</b>														
R3/51	BEDROOM	W3/51	14.25	8.13	42.95%	0.77	0.54	29.74%	106.8	89.5	83.80%	59	55.24%	34.08%
<b>2nd Floor</b>														
R3/52	BEDROOM	W4/52	26.38	19.11	27.56%	1.51	1.39	7.76%	149	147	98.66%	144.1	96.71%	1.97%
		W5/52	84.25	84.25	>27									
<b>Gnd Floor</b>														
R5/60	UNKNOWN	W6/60	8.82	5.49	37.76%	2.30	1.80	21.53%	214.2	195.3	91.18%	194.7	90.90%	0.31%
		W7/60	27.10	19.25	28.97%									
<b>1st Floor</b>														
R6/61	BEDROOM	W9/61	30.43	21.82	28.29%	1.96	1.51	23.12%	125.2	120	95.85%	116.1	92.73%	3.25%
		W10/61	30.44	22.25	26.91%									
<b>2nd Floor</b>														
R2/62	UNKNOWN	W3/62	31.92	24.23	24.09%	2.00	1.58	21.06%	58.4	55.5	95.03%	55.4	94.86%	0.18%
		W4/62	31.91	24.46	23.35%									
<b>100 Bollo Lane BRE_07-08</b>														
<b>3rd Floor</b>														
R1/33	LKD	W1/33	39.22	39.21	>27	3.67	3.48	5.34%	178.3	176.4	98.93%	170.2	95.46%	3.51%
		W2/33	35.21	31.26	>27									
R2/33	BEDROOM	W3/33	34.21	30.02	>27	2.59	2.31	10.77%	96.8	88.7	91.63%	88.7	91.63%	0.00%
		W5/33	29.17	24.60	15.67%									
R4/33	LKD	W5/33	29.17	24.60	15.67%	1.93	1.69	12.51%	194.4	188.7	97.07%	178.6	91.87%	5.35%
R5/33	BEDROOM	W6/33	26.48	21.90	17.30%	2.15	1.85	14.06%	96.8	72.6	75.00%	72.6	75.00%	0.00%
R6/33	LKD	W7/33	23.83	19.28	19.09%	1.69	1.44	14.51%	194.4	181.5	93.36%	179.8	92.49%	0.94%
R7/33	BEDROOM	W8/33	21.49	17.05	20.66%	1.83	1.51	17.37%	96.8	91	94.01%	91	94.01%	0.00%
R8/33	LKD	W9/33	32.34	29.57	>27	3.71	3.41	8.14%	238.8	236.7	99.12%	236.7	99.12%	0.00%
		W10/33	33.73	30.42	>27									
		W11/33	21.81	14.16	35.08%									
R9/33	BEDROOM	W12/33	20.59	12.68	38.42%	2.13	1.74	18.40%	148.6	1415.3	952.42%	1410.6	949.26%	0.33%
		W13/33	20.49	18.14	11.47%									
R10/33	LKD	W14/33	20.70	16.21	21.69%	2.88	2.58	10.61%	303.4	3114.3	1026.47%	3113.6	1026.24%	0.02%
		W15/33	21.95	15.70	28.47%									
		W16/33	25.95	25.95	0.00%									
<b>4th Floor</b>														
R1/34	LKD	W1/34	39.25	39.24	>27	4.02	3.82	5.00%	178.3	177.6	99.61%	171.8	96.35%	3.27%
		W2/34	35.59	32.15	>27									
R2/34	BEDROOM	W3/34	34.41	30.76	>27	2.61	2.36	9.39%	96.8	89	91.94%	89	91.94%	0.00%
R4/34	LKD	W5/34	29.34	25.37	13.53%	1.94	1.73	10.90%	194.4	188.7	97.07%	182.5	93.88%	3.29%
R5/34	BEDROOM	W6/34	26.62	22.64	14.95%	2.16	1.89	12.24%	96.8	72.6	75.00%	72.6	75.00%	0.00%
R6/34	LKD	W7/34	23.91	19.96	16.52%	1.70	1.48	12.63%	194.4	181.7	93.47%	181.2	93.21%	0.28%
R7/34	BEDROOM	W8/34	21.52	17.69	17.80%	1.84	1.56	14.98%	96.8	91	94.01%	91	94.01%	0.00%
		W9/34	33.37	30.93	>27									
R8/34	LKD	W10/34	34.64	31.71	>27	3.71	3.31	10.78%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W11/34	21.87	15.04	31.23%									
		W12/34	20.65	13.66	33.85%									
R9/34	BEDROOM	W13/34	20.55	18.58	9.59%	1.07	1.02	4.57%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
R10/34	LKD	W14/34	20.76	16.88	18.69%	2.89	2.62	9.42%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W15/34	22.02	16.57	24.75%									
		W16/34	26.08	26.08	0.00%									
<b>5th Floor</b>														
R1/35	LKD	W1/35	39.28	39.28	>27	4.03	3.86	4.25%	178.3	177.8	99.72%	173.2	97.14%	2.59%
		W2/35	35.81	32.89	>27									
R2/35	BEDROOM	W3/35	34.64	31.56	>27	2.61	2.41	7.92%	96.8	89	91.94%	89	91.94%	0.00%

Room/Floor	Room Use	Window	%VSC			% Daylight Factor			Daylight Distribution					
			Exist	Prop	% Loss	Exist	Prop	% Loss	Room Area sq ft	Existing Area sq ft	Existing % of Room Area	Proposed Area sq ft	Proposed % of Room Area	% Loss of Existing
R4/35	LKD	W5/35	29.55	26.21	11.30%	1.94	1.76	9.17%	194.4	188.9	97.17%	186.2	95.78%	1.43%
R5/35	BEDROOM	W6/35	26.79	23.43	12.54%	2.16	1.94	10.22%	96.8	72.7	75.10%	72.7	75.10%	0.00%
R6/35	LKD	W7/35	24.01	20.68	13.87%	1.70	1.52	10.61%	194.4	181.7	93.47%	181.7	93.47%	0.00%
R7/35	BEDROOM	W8/35	21.56	18.34	14.94%	1.84	1.61	12.47%	96.8	91	94.01%	91	94.01%	0.00%
R8/35	LKD	W9/35	34.65	32.56	>27	3.76	3.40	9.37%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W10/35	35.72	33.20	>27									
		W11/35	21.92	16.02	26.92%									
		W12/35	20.70	14.71	28.94%									
R9/35	BEDROOM	W13/35	20.59	19.01	7.67%	1.07	1.03	3.72%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
R10/35	LKD	W14/35	20.81	17.57	15.57%	2.89	2.66	8.05%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W15/35	22.06	17.48	20.76%									
		W16/35	26.22	26.22	0.00%									
<b>6th Floor</b>														
R1/36	LKD	W1/36	39.31	39.31	>27	4.03	3.89	3.45%	178.3	177.9	99.78%	175.2	98.26%	1.52%
		W2/36	36.05	33.69	>27									
R2/36	BEDROOM	W3/36	34.91	32.41	>27	2.62	2.45	6.41%	96.8	89.8	92.77%	89.8	92.77%	0.00%
R4/36	LKD	W5/36	29.82	27.11	>27	1.95	1.81	7.38%	194.4	189.2	97.33%	188.5	96.97%	0.37%
R5/36	BEDROOM	W6/36	27.00	24.28	10.07%	2.17	1.99	8.25%	96.8	72.7	75.10%	72.7	75.10%	0.00%
R6/36	LKD	W7/36	24.14	21.44	11.18%	1.70	1.56	8.53%	194.4	181.7	93.47%	181.7	93.47%	0.00%
R7/36	BEDROOM	W8/36	21.61	19.01	12.03%	1.84	1.66	9.96%	96.8	91	94.01%	91	94.01%	0.00%
R8/36	LKD	W9/36	36.14	34.43	>27	3.81	3.51	7.86%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W10/36	36.90	34.82	>27									
		W11/36	21.96	17.05	22.36%									
		W12/36	20.74	15.82	23.72%									
R9/36	BEDROOM	W13/36	20.63	19.43	5.82%	1.08	1.04	2.97%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
R10/36	LKD	W14/36	20.85	18.26	12.42%	3.06	2.86	6.48%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W15/36	22.10	18.40	16.74%									
		W16/36	26.37	26.37	0.00%									
<b>7th Floor</b>														
R1/37	LKD	W1/37	39.35	39.35	>27	3.66	3.57	2.67%	178.3	177.9	99.78%	177.9	99.78%	0.00%
		W2/37	36.34	34.51	>27									
R2/37	BEDROOM	W3/37	35.24	33.30	>27	2.36	2.25	4.95%	96.8	90.2	93.18%	90.2	93.18%	0.00%
R4/37	LKD	W5/37	30.18	28.08	>27	1.78	1.68	5.67%	194.4	189.8	97.63%	189.8	97.63%	0.00%
R6/37	LKD	W7/37	24.32	22.25	8.51%	1.55	1.45	6.52%	194.4	182	93.62%	182	93.62%	0.00%
R7/37	BEDROOM	W8/37	21.69	19.69	9.22%	1.66	1.53	7.60%	96.8	91.1	94.11%	91.1	94.11%	0.00%
R8/37	LKD	W9/37	37.67	36.33	>27	3.51	3.29	6.11%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W10/37	37.99	36.36	>27									
		W11/37	21.00	17.13	18.43%									
		W12/37	19.77	15.94	19.37%									
R9/37	BEDROOM	W13/37	20.51	19.68	4.05%	0.98	0.95	2.15%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
R10/37	LKD	W14/37	19.86	17.91	9.82%	2.77	2.63	5.03%	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
		W15/37	21.06	18.23	13.44%									
		W16/37	26.55	26.55	0.00%									
<b>8th Floor</b>														
R1/38	LKD	W1/38	38.94	37.99	>27	4.67	4.54	2.78%	326.6	3011.1	921.95%	3011.1	921.95%	0.00%
		W2/38	38.95	37.80	>27									
		W3/38	32.05	29.36	>27									
		W4/38	30.17	27.55	>27									
R2/38	BEDROOM	W5/38	22.70	22.21	2.16%	1.09	1.08	1.19%	135.7	1415.3	1042.96%	1410.6	1039.50%	0.33%
R3/38	LKD	W6/38	22.69	21.41	5.64%	3.21	3.12	2.74%	287.5	3114.3	1083.23%	3113.6	1082.99%	0.02%
		W7/38	24.13	22.21	7.96%									
		W8/38	26.78	26.78	0.00%									
<b>9th Floor</b>														
R1/39	LKD	W1/39	38.93	38.31	>27	3.98	3.87	2.71%	326.6	3011.1	921.95%	3011.1	921.95%	0.00%
		W2/39	38.94	38.19	>27									
		W3/39	22.05	20.35	7.71%									
		W4/39	20.83	19.19	7.87%									
R2/39	BEDROOM	W5/39	20.67	20.45	1.06%	1.08	1.07	0.74%	135.7	1415.3	1042.96%	1410.6	1039.50%	0.33%
R3/39	LKD	W6/39	20.35	19.75	2.95%	3.04	2.99	1.68%	287.5	3114.3	1083.23%	3113.6	1082.99%	0.02%
		W7/39	21.58	20.59	4.59%									
		W8/39	27.03	27.03	>27									
<b>10th Floor</b>														
R1/40	LKD	W1/40	39.04	38.73	>27	3.90	3.86	0.95%	326.6	3011.1	921.95%	3011.1	921.95%	0.00%
		W2/40	39.04	38.67	>27									
		W3/40	22.34	21.52	3.67%									
		W4/40	20.95	20.18	3.68%									
R2/40	BEDROOM	W5/40	20.75	20.71	0.19%	1.08	1.08	0.19%	135.7	1415.3	1042.96%	1410.6	1039.50%	0.33%
R3/40	LKD	W6/40	22.62	22.30	1.41%	3.23	3.21	0.65%	287.5	3114.3	1083.23%	3113.6	1082.99%	0.02%
		W7/40	24.13	23.59	2.24%									
		W8/40	27.31	27.31	>27									

Room/Floor	Room Use	Window	%VSC			% Daylight Factor			Daylight Distribution					
			Exist	Prop	% Loss	Exist	Prop	% Loss	Room Area sq ft	Existing Area sq ft	Existing % of Room Area	Proposed Area sq ft	Proposed % of Room Area	% Loss of Existing
<b>11th Floor</b>														
R1/41	LKD	W1/41	39.03	38.96	>27	3.88	3.88	0.13%	326.6	3011.1	921.95%	3011.1	921.95%	0.00%
		W2/41	39.03	38.95	>27									
		W3/41	22.05	21.88	0.77%									
		W4/41	20.84	20.68	0.77%									
R2/41	BEDROOM	W5/41	20.53	20.53	0.00%	1.08	1.08	0.09%	135.7	1415.3	1042.96%	1410.6	1039.50%	0.33%
R3/41	LKD	W6/41	20.36	20.36	0.00%	3.06	3.06	0.10%	287.5	3114.3	1083.23%	3113.6	1082.99%	0.02%
		W7/41	21.58	21.56	0.09%									
		W8/41	27.64	27.64	>27									
<b>12th Floor</b>														
R1/42	LKD	W1/42	39.14	39.14	>27	3.90	3.90	0.00%	326.6	3011.1	921.95%	3011.1	921.95%	0.00%
		W2/42	39.13	39.13	>27									
		W3/42	22.25	22.25	0.00%									
		W4/42	20.86	20.86	0.00%									
R2/42	BEDROOM	W5/42	20.06	20.06	0.00%	1.08	1.08	0.00%	135.7	1415.3	1042.96%	1410.6	1039.50%	0.33%
R3/42	LKD	W6/42	20.98	20.98	0.00%	3.13	3.13	0.00%	287.5	3114.3	1083.23%	3113.6	1082.99%	0.02%
		W7/42	22.37	22.37	0.00%									
		W8/42	27.99	27.99	>27									
<b>13th Floor</b>														
R1/43	LKD	W1/43	39.12	39.12	>27	3.84	3.84	0.00%	326.6	3011.1	921.95%	3011.1	921.95%	0.00%
		W2/43	39.11	39.11	>27									
		W3/43	21.07	21.07	0.00%									
		W4/43	19.71	19.71	0.00%									
R2/43	BEDROOM	W5/43	14.68	14.68	0.00%	0.78	0.78	0.00%	135.7	1415.3	1042.96%	1410.6	1039.50%	0.33%
R3/43	LKD	W6/43	19.83	19.83	0.00%	3.09	3.09	0.00%	287.5	3114.3	1083.23%	3113.6	1082.99%	0.02%
		W7/43	21.20	21.20	0.00%									
		W8/43	28.40	28.40	>27									
<b>95 Bollo Lane BRE_06</b>														
<b>Gnd Floor</b>														
R1/70	UNKNOWN	W1/70	11.92	11.95	-0.25%	1.64	1.14	30.48%	112.8	105.3	93.35%	93.7	83.07%	11.02%
		W2/70	30.40	13.56	55.39%									
		W3/70	30.42	12.94	57.46%									
		W4/70	30.96	12.50	59.63%									
R2/70	UNKNOWN	W5/70	1.97	0.47	76.14%	0.09	0.06	35.48%	57.9	22.5	38.86%	10	17.27%	55.56%
<b>1st Floor</b>														
R1/71	UNKNOWN	W2/71	34.29	14.16	58.71%	0.96	0.55	43.41%	112.8	97.6	86.52%	55.3	49.02%	43.34%
R2/71	UNKNOWN	W1/71	23.98	16.74	30.19%	0.38	0.30	21.00%	32.7	8.1	24.77%	0	0.00%	100.00%

**93 Bollo Lane, South Acton, London**  
**Adjoining owners sunlight results**  
**Job 11 15 June 2021**

Available sunlight as a percentage of  
annual unobstructed total (1486.0 Hrs)

Room use	Window Ref	Existing %			Proposed %			% Loss of Summer	% Loss of Winter	% Loss of Total
		Summer	Winter	Total	Summer	Winter	Total			
<b>42 Weston Road BRE_05-06</b>										
<b>Gnd Floor</b>										
KITCHEN	W1/20	2.00	0.00	2.00	2.00	0.00	2.00	0.00%	0.00%	0.00%
KITCHEN	W2/20	22.00	6.00	28.00	15.00	5.00	20.00	31.82%	16.67%	28.57%
<b>48 Weston Road BRE_05-06</b>										
<b>2nd Floor</b>										
BEDROOM	W4/12	24.00	6.00	30.00	17.00	6.00	23.00	29.17%	0.00%	23.33%
BEDROOM	W27/12	46.00	23.00	69.00	46.00	23.00	69.00	0.00%	0.00%	0.00%
BEDROOM	W28/12	52.00	23.00	75.00	52.00	23.00	75.00	0.00%	0.00%	0.00%
<b>50 Weston Road BRE_05-06</b>										
<b>Gnd Floor</b>										
LIVINGROOM	W4/10	2.00	0.00	2.00	0.00	0.00	0.00	100.00%	0.00%	100.00%
LIVINGROOM	W16/10	39.00	17.00	56.00	39.00	17.00	56.00	0.00%	0.00%	0.00%
LIVINGROOM	W17/10	39.00	17.00	56.00	39.00	17.00	56.00	0.00%	0.00%	0.00%
<b>2nd Floor</b>										
BEDROOM	W5/12	23.00	6.00	29.00	17.00	6.00	23.00	26.09%	0.00%	20.69%
BEDROOM	W7/12	24.00	6.00	30.00	17.00	6.00	23.00	29.17%	0.00%	23.33%
BEDROOM	W26/12	58.00	26.00	84.00	58.00	26.00	84.00	0.00%	0.00%	0.00%
<b>52 Weston Road BRE_05-06</b>										
<b>2nd Floor</b>										
UNKNOWN	W9/12	23.00	6.00	29.00	18.00	6.00	24.00	21.74%	0.00%	17.24%
UNKNOWN	W24/12	46.00	23.00	69.00	46.00	23.00	69.00	0.00%	0.00%	0.00%
UNKNOWN	W25/12	48.00	23.00	71.00	48.00	23.00	71.00	0.00%	0.00%	0.00%
<b>54 Weston Road BRE_05-06</b>										
<b>2nd Floor</b>										
UNKNOWN	W10/12	22.00	6.00	28.00	18.00	6.00	24.00	18.18%	0.00%	14.29%
UNKNOWN	W22/12	58.00	26.00	84.00	58.00	26.00	84.00	0.00%	0.00%	0.00%
UNKNOWN	W23/12	58.00	26.00	84.00	58.00	26.00	84.00	0.00%	0.00%	0.00%
UNKNOWN	W2/22	57.00	23.00	80.00	53.00	23.00	76.00	7.02%	0.00%	5.00%
UNKNOWN	W3/22	22.00	6.00	28.00	18.00	6.00	24.00	18.18%	0.00%	14.29%
<b>62 Weston Road BRE_05-06</b>										
<b>2nd Floor</b>										
KD	W12/12	23.00	4.00	27.00	21.00	4.00	25.00	8.70%	0.00%	7.41%
KD	W21/12	58.00	26.00	84.00	58.00	26.00	84.00	0.00%	0.00%	0.00%



Room use	Window Ref	Existing %			Proposed %			% Loss of Summer	% Loss of Winter	% Loss of Total
		Summer	Winter	Total	Summer	Winter	Total			
<b>64 Weston Road BRE_05-06</b>										
<b>Gnd Floor</b>										
LIVINGROOM	W11/10	0.00	0.00	0.00	0.00	0.00	0.00	0.00%	0.00%	0.00%
LIVINGROOM	W14/10	36.00	17.00	53.00	36.00	17.00	53.00	0.00%	0.00%	0.00%
LIVINGROOM	W15/10	39.00	17.00	56.00	39.00	17.00	56.00	0.00%	0.00%	0.00%
<b>2nd Floor</b>										
UNKNOWN	W13/12	23.00	7.00	30.00	22.00	7.00	29.00	4.35%	0.00%	3.33%
UNKNOWN	W14/12	62.00	26.00	88.00	61.00	26.00	87.00	1.61%	0.00%	1.14%
BEDROOM	W15/12	21.00	0.00	21.00	20.00	0.00	20.00	4.76%	0.00%	4.76%
BEDROOM	W20/12	43.00	22.00	65.00	43.00	22.00	65.00	0.00%	0.00%	0.00%
<b>Gnd Floor</b>										
KITCHEN	W28/20	20.00	5.00	25.00	19.00	5.00	24.00	5.00%	0.00%	4.00%
KITCHEN	W29/20	1.00	0.00	1.00	1.00	0.00	1.00	0.00%	0.00%	0.00%
<b>66 Weston Road BRE_05-06</b>										
<b>2nd Floor</b>										
BEDROOM	W16/12	1.00	0.00	1.00	0.00	0.00	0.00	100.00%	0.00%	100.00%
BEDROOM	W19/12	58.00	26.00	84.00	58.00	26.00	84.00	0.00%	0.00%	0.00%
<b>72 Weston Road BRE_05-06</b>										
<b>Gnd Floor</b>										
LIVINGROOM	W2/50	0.00	0.00	0.00	0.00	0.00	0.00	0.00%	0.00%	0.00%
LIVINGROOM	W4/50	32.00	18.00	50.00	32.00	18.00	50.00	0.00%	0.00%	0.00%
LIVINGROOM	W5/50	32.00	18.00	50.00	32.00	18.00	50.00	0.00%	0.00%	0.00%
<b>2nd Floor</b>										
BEDROOM	W3/52	20.00	1.00	21.00	20.00	1.00	21.00	0.00%	0.00%	0.00%
BEDROOM	W6/52	42.00	24.00	66.00	42.00	24.00	66.00	0.00%	0.00%	0.00%
<b>Gnd Floor</b>										
KITCHEN	W3/60	19.00	1.00	20.00	19.00	1.00	20.00	0.00%	0.00%	0.00%
KITCHEN	W4/60	0.00	0.00	0.00	0.00	0.00	0.00	0.00%	0.00%	0.00%
<b>2nd Floor</b>										
BEDROOM	W1/62	21.00	6.00	27.00	21.00	6.00	27.00	0.00%	0.00%	0.00%
BEDROOM	W2/62	26.00	4.00	30.00	26.00	4.00	30.00	0.00%	0.00%	0.00%
<b>74 Weston Road BRE_05-06</b>										
<b>2nd Floor</b>										
BEDROOM	W4/52	0.00	0.00	0.00	0.00	0.00	0.00	0.00%	0.00%	0.00%
BEDROOM	W5/52	60.00	26.00	86.00	60.00	26.00	86.00	0.00%	0.00%	0.00%
<b>100 Bollo Lane BRE_07-08</b>										
<b>3rd Floor</b>										
LKD	W1/33	46.00	22.00	68.00	46.00	22.00	68.00	0.00%	0.00%	0.00%
LKD	W2/33	20.00	3.00	23.00	20.00	3.00	23.00	0.00%	0.00%	0.00%
LKD	W9/33	42.00	9.00	51.00	38.00	9.00	47.00	9.52%	0.00%	7.84%
LKD	W10/33	44.00	11.00	55.00	39.00	11.00	50.00	11.36%	0.00%	9.09%
LKD	W11/33	10.00	3.00	13.00	5.00	3.00	8.00	50.00%	0.00%	38.46%
<b>4th Floor</b>										
LKD	W1/34	46.00	22.00	68.00	46.00	22.00	68.00	0.00%	0.00%	0.00%
LKD	W2/34	20.00	2.00	22.00	20.00	2.00	22.00	0.00%	0.00%	0.00%
LKD	W9/34	44.00	10.00	54.00	41.00	10.00	51.00	6.82%	0.00%	5.56%

Room use	Window Ref	Existing %			Proposed %			% Loss of Summer	% Loss of Winter	% Loss of Total
		Summer	Winter	Total	Summer	Winter	Total			
LKD	W10/34	45.00	13.00	58.00	40.00	13.00	53.00	11.11%	0.00%	8.62%
LKD	W11/34	10.00	3.00	13.00	5.00	3.00	8.00	50.00%	0.00%	38.46%
LKD	W12/34	10.00	1.00	11.00	5.00	1.00	6.00	50.00%	0.00%	45.45%
<b>5th Floor</b>										
LKD	W1/35	46.00	23.00	69.00	46.00	23.00	69.00	0.00%	0.00%	0.00%
LKD	W2/35	20.00	2.00	22.00	20.00	2.00	22.00	0.00%	0.00%	0.00%
LKD	W9/35	45.00	13.00	58.00	42.00	13.00	55.00	6.67%	0.00%	5.17%
LKD	W10/35	45.00	16.00	61.00	40.00	16.00	56.00	11.11%	0.00%	8.20%
LKD	W11/35	10.00	3.00	13.00	5.00	3.00	8.00	50.00%	0.00%	38.46%
LKD	W12/35	10.00	1.00	11.00	5.00	1.00	6.00	50.00%	0.00%	45.45%
<b>6th Floor</b>										
LKD	W1/36	46.00	23.00	69.00	46.00	23.00	69.00	0.00%	0.00%	0.00%
LKD	W2/36	20.00	2.00	22.00	20.00	2.00	22.00	0.00%	0.00%	0.00%
LKD	W9/36	45.00	19.00	64.00	43.00	19.00	62.00	4.44%	0.00%	3.13%
LKD	W10/36	45.00	20.00	65.00	40.00	20.00	60.00	11.11%	0.00%	7.69%
LKD	W11/36	10.00	3.00	13.00	5.00	3.00	8.00	50.00%	0.00%	38.46%
LKD	W12/36	10.00	1.00	11.00	5.00	1.00	6.00	50.00%	0.00%	45.45%
<b>7th Floor</b>										
LKD	W1/37	46.00	23.00	69.00	46.00	23.00	69.00	0.00%	0.00%	0.00%
LKD	W2/37	20.00	2.00	22.00	20.00	2.00	22.00	0.00%	0.00%	0.00%
LKD	W9/37	45.00	23.00	68.00	43.00	23.00	66.00	4.44%	0.00%	2.94%
LKD	W10/37	45.00	23.00	68.00	42.00	23.00	65.00	6.67%	0.00%	4.41%
LKD	W11/37	9.00	3.00	12.00	4.00	3.00	7.00	55.56%	0.00%	41.67%
LKD	W12/37	8.00	1.00	9.00	3.00	1.00	4.00	62.50%	0.00%	55.56%
<b>8th Floor</b>										
LKD	W1/38	45.00	23.00	68.00	44.00	23.00	67.00	2.22%	0.00%	1.47%
LKD	W2/38	45.00	23.00	68.00	44.00	23.00	67.00	2.22%	0.00%	1.47%
LKD	W3/38	15.00	3.00	18.00	12.00	3.00	15.00	20.00%	0.00%	16.67%
LKD	W4/38	16.00	1.00	17.00	13.00	1.00	14.00	18.75%	0.00%	17.65%
<b>9th Floor</b>										
LKD	W1/39	45.00	23.00	68.00	44.00	23.00	67.00	2.22%	0.00%	1.47%
LKD	W2/39	45.00	23.00	68.00	44.00	23.00	67.00	2.22%	0.00%	1.47%
LKD	W3/39	10.00	3.00	13.00	9.00	3.00	12.00	10.00%	0.00%	7.69%
LKD	W4/39	10.00	1.00	11.00	9.00	1.00	10.00	10.00%	0.00%	9.09%
<b>10th Floor</b>										
LKD	W1/40	45.00	23.00	68.00	44.00	23.00	67.00	2.22%	0.00%	1.47%
LKD	W2/40	45.00	23.00	68.00	44.00	23.00	67.00	2.22%	0.00%	1.47%
LKD	W3/40	13.00	3.00	16.00	13.00	3.00	16.00	0.00%	0.00%	0.00%
LKD	W4/40	10.00	1.00	11.00	10.00	1.00	11.00	0.00%	0.00%	0.00%
<b>11th Floor</b>										
LKD	W1/41	45.00	23.00	68.00	45.00	23.00	68.00	0.00%	0.00%	0.00%
LKD	W2/41	45.00	23.00	68.00	45.00	23.00	68.00	0.00%	0.00%	0.00%
LKD	W3/41	10.00	3.00	13.00	10.00	3.00	13.00	0.00%	0.00%	0.00%
LKD	W4/41	10.00	1.00	11.00	10.00	1.00	11.00	0.00%	0.00%	0.00%

Room use	Window Ref	Existing %			Proposed %			% Loss of Summer	% Loss of Winter	% Loss of Total
		Summer	Winter	Total	Summer	Winter	Total			
<b>12th Floor</b>										
LKD	W1/42	45.00	23.00	68.00	45.00	23.00	68.00	0.00%	0.00%	0.00%
LKD	W2/42	45.00	23.00	68.00	45.00	23.00	68.00	0.00%	0.00%	0.00%
LKD	W3/42	13.00	3.00	16.00	13.00	3.00	16.00	0.00%	0.00%	0.00%
LKD	W4/42	10.00	1.00	11.00	10.00	1.00	11.00	0.00%	0.00%	0.00%
<b>13th Floor</b>										
LKD	W1/43	45.00	23.00	68.00	45.00	23.00	68.00	0.00%	0.00%	0.00%
LKD	W2/43	45.00	23.00	68.00	45.00	23.00	68.00	0.00%	0.00%	0.00%
LKD	W3/43	9.00	3.00	12.00	9.00	3.00	12.00	0.00%	0.00%	0.00%
LKD	W4/43	8.00	1.00	9.00	8.00	1.00	9.00	0.00%	0.00%	0.00%
<b>95 Bollo Lane BRE_06</b>										
<b>Gnd Floor</b>										
UNKNOWN	W1/70	17.00	6.00	23.00	17.00	6.00	23.00	0.00%	0.00%	0.00%
UNKNOWN	W2/70	42.00	14.00	56.00	16.00	10.00	26.00	61.90%	28.57%	53.57%
UNKNOWN	W3/70	42.00	14.00	56.00	16.00	10.00	26.00	61.90%	28.57%	53.57%
UNKNOWN	W4/70	42.00	15.00	57.00	15.00	11.00	26.00	64.29%	26.67%	54.39%
UNKNOWN	W5/70	2.00	0.00	2.00	0.00	0.00	0.00	100.00%	0.00%	100.00%
<b>1st Floor</b>										
UNKNOWN	W2/71	43.00	16.00	59.00	16.00	11.00	27.00	62.79%	31.25%	54.24%
UNKNOWN	W1/71	26.00	14.00	40.00	15.00	13.00	28.00	42.31%	7.14%	30.00%

**Bollo Lane development, Ealing , London**  
**Internal sunlight & daylight results**  
**Job 14 18 June 2021**

Room/Floor	Room Use	Window	Daylight Distribution					%Sun		
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
<b>Bollo Lane development BO64_14_BRE_01-12</b>										
<b>1st Floor</b>										
R1/801	LKD	W1/801	14.98	1.67	297.70	203.90	68.49%	0	0	0
		W2/801	11.70					6	0	6
		W3/801	23.23					23	5	28
		W4/801	23.74					0	0	0
R2/801	BEDROOM	W5/801	35.66	4.11	90.00	88.20	98.00%	32	14	46
R3/801	BEDROOM	W6/801	27.45	4.06	127.00	119.10	93.78%	27	6	33
R4/801	BEDROOM	W7/801	19.21	4.11	112.50	111.90	99.47%	12	8	20
R5/801	LKD	W8/801	12.85	3.14	245.40	244.50	99.63%	6	0	6
		W9/801	27.40					27	5	32
R6/801	LKD	W10/801	19.18	2.33	217.60	217.40	99.91%	12	7	19
R7/801	BEDROOM	W11/801	12.95	4.57	150.70	147.40	97.81%	6	0	6
		W12/801	27.38					27	5	32
R8/801	BEDROOM	W13/801	19.16	3.99	116.70	116.00	99.40%	12	7	19
R9/801	LKD	W14/801	12.95	3.09	250.30	249.40	99.64%	6	0	6
		W15/801	27.37					27	5	32
R10/801	LD	W16/801	19.12	3.51	140.40	140.10	99.79%	12	7	19
R11/801	BEDROOM	W17/801	12.90	4.60	125.80	125.20	99.52%	6	0	6
		W18/801	35.32					32	14	46
R12/801	BEDROOM	W19/801	22.51	2.43	117.90	99.70	84.56%	N/A	N/A	N/A
R13/801	LKD	W20/801	38.60	6.20	245.10	241.40	98.49%	38	19	57
		W21/801	11.50					1	13	14
		W22/801	7.02					0	0	0
		W23/801	25.75					24	13	37
R14/801	BEDROOM	W24/801	24.98	1.91	148.00	106.00	71.62%	22	12	34
R15/801	BEDROOM	W25/801	23.19	1.80	148.00	89.00	60.14%	20	12	32
R16/801	LKD	W26/801	22.09	3.94	245.10	243.10	99.18%	21	12	33
		W27/801	4.12					0	0	0
		W28/801	6.33					0	4	4
		W29/801	27.58					1	0	1
R17/801	BEDROOM	W30/801	25.12	4.03	119.10	117.50	98.66%	N/A	N/A	N/A
R18/801	LKD	W31/801	8.17	1.26	281.50	209.40	74.39%	1	0	1
		W32/801	1.90					0	0	0
R19/801	BEDROOM	W33/801	24.95	3.09	92.40	86.50	93.61%	N/A	N/A	N/A
R20/801	BEDROOM	W34/801	16.99	2.19	149.80	121.70	81.24%	N/A	N/A	N/A
R21/801	LKD	W35/801	11.90	3.47	326.00	324.10	99.42%	5	0	5
		W36/801	14.12					3	0	3
		W37/801	4.58					0	0	0
		W38/801	33.21					3	0	3
R22/801	BEDROOM	W39/801	33.00	4.17	84.20	82.10	97.51%	N/A	N/A	N/A
R23/801	BEDROOM	W40/801	31.06	3.98	115.30	111.20	96.44%	N/A	N/A	N/A
R24/801	LKD	W41/801	14.75	2.13	211.80	202.50	95.61%	N/A	N/A	N/A
R25/801	BEDROOM	W42/801	4.99	3.45	142.30	133.20	93.61%	2	0	2
		W43/801	34.10					8	0	8
R26/801	BEDROOM	W44/801	33.02	4.82	124.50	119.30	95.82%	N/A	N/A	N/A
R27/801	BEDROOM	W45/801	16.24	3.70	112.60	111.80	99.29%	N/A	N/A	N/A

Room/Floor	Room Use	Window	Daylight Distribution					%Sun		
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
R28/801	LKD	W46/801	6.30	3.31	245.00	245.00	100.00%	3	1	4
		W47/801	35.55					8	0	8
R29/801	BEDROOM	W48/801	35.69	2.84	138.00	135.50	98.19%	N/A	N/A	N/A
R30/801	BEDROOM	W49/801	35.86	3.35	116.70	112.90	96.74%	N/A	N/A	N/A
R31/801	BEDROOM	W50/801	9.87	1.62	84.10	79.00	93.94%	N/A	N/A	N/A
R32/801	LKD	W51/801	14.03	2.02	290.50	266.60	91.77%	N/A	N/A	N/A
<b>2nd Floor</b>										
R1/802	LKD	W1/802	15.55	1.69	297.70	203.90	68.49%	0	0	0
		W2/802	12.01					6	0	6
		W3/802	23.75					23	5	28
		W4/802	24.12					0	0	0
R2/802	BEDROOM	W5/802	36.43	4.17	90.00	88.20	98.00%	32	15	47
R3/802	BEDROOM	W6/802	28.10	4.12	127.00	119.10	93.78%	27	7	34
R4/802	BEDROOM	W7/802	19.92	4.20	112.50	111.90	99.47%	12	9	21
R5/802	LKD	W8/802	13.20	3.18	245.40	244.50	99.63%	6	0	6
		W9/802	28.08					27	7	34
R6/802	LKD	W10/802	19.92	2.38	217.60	217.40	99.91%	12	9	21
		W11/802	13.31					6	0	6
R7/802	BEDROOM	W12/802	28.09	4.64	150.70	147.40	97.81%	27	7	34
		W13/802	19.93					12	9	21
R9/802	LKD	W14/802	13.32	3.13	250.30	249.40	99.64%	6	0	6
		W15/802	28.09					27	7	34
R10/802	LD	W16/802	19.92	3.60	140.40	140.10	99.79%	12	9	21
R11/802	BEDROOM	W17/802	13.31	4.68	125.80	125.20	99.52%	6	0	6
		W18/802	36.17					32	15	47
R12/802	BEDROOM	W19/802	22.93	2.45	117.90	99.70	84.56%	N/A	N/A	N/A
R13/802	LKD	W20/802	39.45	6.40	245.10	243.00	99.14%	38	19	57
		W21/802	12.25					1	14	15
		W22/802	7.36					0	0	0
		W23/802	26.83					24	14	38
R14/802	BEDROOM	W24/802	26.07	1.99	148.00	114.30	77.23%	23	13	36
R15/802	BEDROOM	W25/802	24.57	1.89	148.00	98.60	66.62%	20	13	33
R16/802	LKD	W26/802	23.64	4.23	245.10	243.10	99.18%	21	14	35
		W27/802	4.28					0	0	0
		W28/802	7.45					0	5	5
		W29/802	28.22					1	0	1
R17/802	BEDROOM	W30/802	25.75	4.12	119.10	117.60	98.74%	N/A	N/A	N/A
R18/802	LKD	W31/802	8.41	1.28	281.50	209.40	74.39%	1	0	1
		W32/802	2.09					0	0	0
R19/802	BEDROOM	W33/802	25.61	3.14	92.40	87.60	94.81%	N/A	N/A	N/A
R20/802	BEDROOM	W34/802	17.37	2.19	152.40	122.10	80.12%	N/A	N/A	N/A
R21/802	LKD	W35/802	12.56	3.57	326.00	324.10	99.42%	6	0	6
		W36/802	14.67					3	0	3
		W37/802	4.88					0	0	0
		W38/802	34.10					3	0	3
R22/802	BEDROOM	W39/802	33.92	4.25	84.20	82.10	97.51%	N/A	N/A	N/A
R23/802	BEDROOM	W40/802	32.01	4.06	115.30	111.20	96.44%	N/A	N/A	N/A
R24/802	LKD	W41/802	15.57	2.20	211.80	202.50	95.61%	N/A	N/A	N/A
R25/802	BEDROOM	W42/802	5.14	3.53	142.30	136.70	96.06%	2	0	2
		W43/802	35.17					8	0	8
R26/802	BEDROOM	W44/802	34.06	4.93	124.50	119.60	96.06%	N/A	N/A	N/A
R27/802	BEDROOM	W45/802	17.16	3.83	112.60	111.80	99.29%	N/A	N/A	N/A
R28/802	LKD	W46/802	6.53	3.40	245.00	245.00	100.00%	3	1	4
		W47/802	36.60					8	0	8
R29/802	BEDROOM	W48/802	36.74	2.92	138.00	135.50	98.19%	N/A	N/A	N/A
R30/802	BEDROOM	W49/802	36.88	3.45	116.70	112.90	96.74%	N/A	N/A	N/A
R31/802	BEDROOM	W50/802	10.16	1.64	84.10	79.00	93.94%	N/A	N/A	N/A
R32/802	LKD	W51/802	14.68	2.08	290.50	266.60	91.77%	N/A	N/A	N/A

Room/Floor	Room Use	Window	Daylight Distribution				%Sun			
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
<b>3rd Floor</b>										
R1/803	LKD	W1/803	15.56	1.69	297.70	203.90	68.49%	0	0	0
		W2/803	12.01					6	0	6
		W3/803	23.76					23	5	28
		W4/803	24.20					0	0	0
R2/803	BEDROOM	W5/803	36.46	4.17	90.00	88.20	98.00%	32	15	47
R3/803	BEDROOM	W6/803	28.11	4.12	127.00	119.10	93.78%	27	7	34
R4/803	BEDROOM	W7/803	19.93	4.20	112.50	111.90	99.47%	12	9	21
R5/803	LKD	W8/803	13.21	3.19	245.40	244.50	99.63%	6	0	6
		W9/803	28.09					27	7	34
R6/803	LKD	W10/803	19.93	2.39	217.60	217.40	99.91%	12	9	21
R7/803	BEDROOM	W11/803	13.33	4.65	150.70	147.40	97.81%	6	0	6
		W12/803	28.09					27	7	34
R8/803	BEDROOM	W13/803	19.94	4.09	116.70	116.00	99.40%	12	9	21
R9/803	LKD	W14/803	13.34	3.14	250.30	249.40	99.64%	6	0	6
		W15/803	28.10					27	7	34
R10/803	LD	W16/803	19.93	3.60	140.40	140.10	99.79%	12	9	21
R11/803	BEDROOM	W17/803	13.33	4.68	125.80	125.20	99.52%	6	0	6
		W18/803	36.23					32	15	47
R12/803	BEDROOM	W19/803	22.96	2.45	117.90	99.70	84.56%	N/A	N/A	N/A
R13/803	LKD	W20/803	39.47	6.53	245.10	243.10	99.18%	38	19	57
		W21/803	12.90					1	15	16
		W22/803	7.36					0	0	0
		W23/803	27.85					25	14	39
R14/803	BEDROOM	W24/803	27.12	2.06	148.00	126.10	85.20%	23	13	36
R15/803	BEDROOM	W25/803	25.88	1.97	148.00	105.70	71.42%	20	13	33
R16/803	LKD	W26/803	25.12	4.49	245.10	243.10	99.18%	21	14	35
		W27/803	4.38					0	0	0
		W28/803	8.54					0	6	6
		W29/803	28.67					1	0	1
R17/803	BEDROOM	W30/803	26.18	4.16	119.10	117.70	98.82%	N/A	N/A	N/A
R18/803	LKD	W31/803	8.52	1.29	281.50	209.40	74.39%	1	0	1
		W32/803	2.29					0	0	0
R19/803	BEDROOM	W33/803	26.04	3.16	92.40	87.40	94.59%	N/A	N/A	N/A
R20/803	BEDROOM	W34/803	17.65	2.21	152.40	122.10	80.12%	N/A	N/A	N/A
R21/803	LKD	W35/803	13.22	3.62	326.00	324.10	99.42%	7	1	8
		W36/803	14.88					3	0	3
		W37/803	5.11					0	0	0
		W38/803	34.52					3	0	3
R22/803	BEDROOM	W39/803	34.32	4.28	84.20	82.10	97.51%	N/A	N/A	N/A
R23/803	BEDROOM	W40/803	32.38	4.10	115.30	111.20	96.44%	N/A	N/A	N/A
R24/803	LKD	W41/803	15.84	2.22	211.80	202.50	95.61%	N/A	N/A	N/A
R25/803	BEDROOM	W42/803	5.20	3.56	142.30	138.40	97.26%	2	0	2
		W43/803	35.57					8	0	8
R26/803	BEDROOM	W44/803	34.44	4.97	124.50	119.90	96.31%	N/A	N/A	N/A
R27/803	BEDROOM	W45/803	17.50	3.87	112.60	111.80	99.29%	N/A	N/A	N/A
R28/803	LKD	W46/803	6.60	3.43	245.00	245.00	100.00%	3	1	4
		W47/803	37.00					8	0	8
R29/803	BEDROOM	W48/803	37.14	2.95	138.00	135.50	98.19%	N/A	N/A	N/A
R30/803	BEDROOM	W49/803	37.27	3.47	116.70	112.90	96.74%	N/A	N/A	N/A
R31/803	BEDROOM	W50/803	10.31	1.66	84.10	79.00	93.94%	N/A	N/A	N/A
R32/803	LKD	W51/803	14.95	2.10	290.50	266.60	91.77%	N/A	N/A	N/A
<b>4th Floor</b>										
R1/804	LKD	W1/804	15.56	1.69	297.70	203.90	68.49%	0	0	0
		W2/804	12.01					6	0	6
		W3/804	23.77					23	5	28
		W4/804	24.39					0	0	0

Room/Floor	Room Use	Window	Daylight Distribution			%Sun				
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
R2/804	BEDROOM	W5/804	36.50	4.17	90.00	88.20	98.00%	32	15	47
R3/804	BEDROOM	W6/804	28.11	4.12	127.00	119.10	93.78%	27	7	34
R4/804	BEDROOM	W7/804	19.93	4.20	112.50	111.90	99.47%	12	9	21
R5/804	LKD	W8/804	13.22	3.19	245.40	244.50	99.63%	6	0	6
		W9/804	28.09					27	7	34
R6/804	LKD	W10/804	19.93	2.39	217.60	217.40	99.91%	12	9	21
R7/804	BEDROOM	W11/804	13.34	4.65	150.70	147.40	97.81%	6	0	6
		W12/804	28.09					27	7	34
R8/804	BEDROOM	W13/804	19.94	4.09	116.70	116.00	99.40%	12	9	21
R9/804	LKD	W14/804	13.35	3.14	250.30	249.40	99.64%	6	0	6
		W15/804	28.10					27	7	34
R10/804	LD	W16/804	19.93	3.60	140.40	140.10	99.79%	12	9	21
R11/804	BEDROOM	W17/804	13.34	4.68	125.80	125.20	99.52%	6	0	6
		W18/804	36.33					32	15	47
R12/804	BEDROOM	W19/804	22.99	2.45	117.90	99.70	84.56%	N/A	N/A	N/A
R13/804	LKD	W20/804	39.48	6.67	245.10	243.10	99.18%	38	19	57
		W21/804	13.60					1	15	16
		W22/804	7.36					0	0	0
		W23/804	28.91					25	15	40
R14/804	BEDROOM	W24/804	28.21	2.13	148.00	142.00	95.95%	24	14	38
R15/804	BEDROOM	W25/804	27.06	2.05	148.00	116.70	78.85%	22	14	36
R16/804	LKD	W26/804	26.35	4.67	245.10	243.10	99.18%	21	15	36
		W27/804	4.55					0	0	0
		W28/804	9.29					0	7	7
		W29/804	29.05					1	0	1
R17/804	BEDROOM	W30/804	26.52	4.19	119.10	117.90	98.99%	N/A	N/A	N/A
R18/804	LKD	W31/804	8.55	1.29	281.50	209.40	74.39%	1	0	1
		W32/804	2.46					0	0	0
R19/804	BEDROOM	W33/804	26.35	3.18	92.40	87.60	94.81%	N/A	N/A	N/A
R20/804	BEDROOM	W34/804	17.90	2.22	152.40	122.10	80.12%	N/A	N/A	N/A
R21/804	LKD	W35/804	13.87	3.66	326.00	324.10	99.42%	7	1	8
		W36/804	14.99					3	0	3
		W37/804	5.29					0	0	0
		W38/804	34.77					3	0	3
R22/804	BEDROOM	W39/804	34.56	4.30	84.20	82.10	97.51%	N/A	N/A	N/A
R23/804	BEDROOM	W40/804	32.59	4.11	115.30	111.20	96.44%	N/A	N/A	N/A
R24/804	LKD	W41/804	15.93	2.23	211.80	202.50	95.61%	N/A	N/A	N/A
R25/804	BEDROOM	W42/804	5.24	3.58	142.30	139.60	98.10%	2	0	2
		W43/804	35.81					8	0	8
R26/804	BEDROOM	W44/804	34.63	4.99	124.50	120.80	97.03%	N/A	N/A	N/A
R27/804	BEDROOM	W45/804	17.67	3.88	112.60	111.80	99.29%	N/A	N/A	N/A
R28/804	LKD	W46/804	6.70	3.44	245.00	245.00	100.00%	3	1	4
		W47/804	37.17					8	0	8
R29/804	BEDROOM	W48/804	37.31	2.95	138.00	135.50	98.19%	N/A	N/A	N/A
R30/804	BEDROOM	W49/804	37.44	3.48	116.70	112.90	96.74%	N/A	N/A	N/A
R31/804	BEDROOM	W50/804	10.44	1.68	84.10	79.00	93.94%	N/A	N/A	N/A
R32/804	LKD	W51/804	15.03	2.11	290.50	266.60	91.77%	N/A	N/A	N/A
<b>5th Floor</b>										
R1/805	LKD	W1/805	15.56	1.69	297.70	203.90	68.49%	0	0	0
		W2/805	12.01					6	0	6
		W3/805	23.82					23	5	28
		W4/805	24.99					0	0	0
R2/805	BEDROOM	W5/805	36.59	4.17	90.00	88.20	98.00%	32	15	47
R3/805	BEDROOM	W6/805	28.12	4.12	127.00	119.10	93.78%	27	7	34
R4/805	BEDROOM	W7/805	19.93	4.20	112.50	111.90	99.47%	12	9	21
R5/805	LKD	W8/805	13.23	3.19	245.40	244.50	99.63%	6	0	6
		W9/805	28.10					27	7	34

Room/Floor	Room Use	Window	Daylight Distribution			%Sun				
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
R6/805	LKD	W10/805	19.93	2.39	217.60	217.40	99.91%	12	9	21
R7/805	BEDROOM	W11/805	13.35	4.65	150.70	147.40	97.81%	6	0	6
		W12/805	28.08					27	7	34
R8/805	BEDROOM	W13/805	19.94	4.09	116.70	116.00	99.40%	12	9	21
R9/805	LKD	W14/805	13.36	3.14	250.30	249.40	99.64%	6	0	6
		W15/805	28.11					27	7	34
R10/805	LD	W16/805	19.93	3.60	140.40	140.10	99.79%	12	9	21
R11/805	BEDROOM	W17/805	13.35	4.68	125.80	125.20	99.52%	6	0	6
		W18/805	36.64					33	15	48
R12/805	BEDROOM	W19/805	23.04	2.45	117.90	99.70	84.56%	N/A	N/A	N/A
R13/805	LKD	W20/805	39.49	6.78	245.10	243.10	99.18%	38	19	57
		W21/805	14.27					1	16	17
		W22/805	7.36					0	0	0
		W23/805	29.79					26	16	42
R14/805	BEDROOM	W24/805	29.12	2.20	148.00	142.00	95.95%	24	15	39
R15/805	BEDROOM	W25/805	28.09	2.12	148.00	121.10	81.82%	23	15	38
R16/805	LKD	W26/805	27.42	4.80	245.10	243.10	99.18%	21	16	37
		W27/805	4.86					0	0	0
		W28/805	9.80					0	8	8
		W29/805	29.46					1	0	1
R17/805	BEDROOM	W30/805	26.88	4.22	119.10	118.00	99.08%	N/A	N/A	N/A
R18/805	LKD	W31/805	8.65	1.30	281.50	209.40	74.39%	2	0	2
		W32/805	2.55					0	0	0
R19/805	BEDROOM	W33/805	26.68	3.19	92.40	87.90	95.13%	N/A	N/A	N/A
R20/805	BEDROOM	W34/805	18.16	2.23	152.40	122.10	80.12%	N/A	N/A	N/A
R21/805	LKD	W35/805	14.56	3.69	326.00	324.10	99.42%	8	1	9
		W36/805	15.08					3	0	3
		W37/805	5.47					0	0	0
		W38/805	35.03					3	0	3
R22/805	BEDROOM	W39/805	34.79	4.31	84.20	82.10	97.51%	N/A	N/A	N/A
R23/805	BEDROOM	W40/805	32.78	4.12	115.30	111.20	96.44%	N/A	N/A	N/A
R24/805	LKD	W41/805	16.00	2.23	211.80	202.70	95.70%	N/A	N/A	N/A
R25/805	BEDROOM	W42/805	5.29	3.60	142.30	139.80	98.24%	2	0	2
		W43/805	36.07					8	0	8
R26/805	BEDROOM	W44/805	34.81	5.00	124.50	121.00	97.19%	N/A	N/A	N/A
R27/805	BEDROOM	W45/805	17.80	3.89	112.60	111.80	99.29%	N/A	N/A	N/A
R28/805	LKD	W46/805	6.96	3.45	245.00	245.00	100.00%	3	1	4
		W47/805	37.30					8	0	8
R29/805	BEDROOM	W48/805	37.44	2.95	138.00	135.50	98.19%	N/A	N/A	N/A
R30/805	BEDROOM	W49/805	37.57	3.48	116.70	112.90	96.74%	N/A	N/A	N/A
R31/805	BEDROOM	W50/805	10.55	1.69	84.10	79.00	93.94%	N/A	N/A	N/A
R32/805	LKD	W51/805	15.06	2.11	290.50	266.60	91.77%	N/A	N/A	N/A
<b>6th Floor</b>										
R1/806	LKD	W1/806	14.92	1.69	297.70	203.90	68.49%	0	0	0
		W2/806	11.42					6	0	6
		W3/806	24.42					25	5	30
		W4/806	28.14					0	0	0
R2/806	BEDROOM	W5/806	36.79	4.14	90.00	88.20	98.00%	33	15	48
R3/806	BEDROOM	W6/806	28.06	4.08	127.00	119.10	93.78%	27	7	34
R4/806	BEDROOM	W7/806	19.93	4.20	112.50	111.90	99.47%	12	9	21
R5/806	LKD	W8/806	13.27	3.19	245.40	244.50	99.63%	6	0	6
		W9/806	28.10					27	7	34
R6/806	LKD	W10/806	19.93	2.39	217.60	217.40	99.91%	12	9	21
R7/806	BEDROOM	W11/806	13.35	4.65	150.70	147.40	97.81%	6	0	6
		W12/806	28.06					27	7	34
R8/806	BEDROOM	W13/806	19.94	4.09	116.70	116.00	99.40%	12	9	21
R9/806	LKD	W14/806	13.36	3.14	250.30	249.40	99.64%	6	0	6
		W15/806	28.12					27	7	34



Room/Floor	Room Use	Window	Daylight Distribution					%Sun		
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
R10/806	LD	W16/806	19.93	3.60	140.40	140.10	99.79%	12	9	21
R11/806	BEDROOM	W17/806	13.35	4.69	125.80	125.20	99.52%	6	0	6
		W18/806	37.66					34	15	49
R12/806	BEDROOM	W19/806	22.84	2.37	117.90	99.70	84.56%	N/A	N/A	N/A
R13/806	LKD	W20/806	39.37	6.36	245.10	242.70	99.02%	38	19	57
		W21/806	12.16					0	15	15
		W22/806	6.11					0	0	0
		W23/806	28.41					21	16	37
R14/806	BEDROOM	W24/806	27.79	1.93	148.00	141.80	95.81%	21	15	36
R15/806	BEDROOM	W25/806	28.97	2.17	148.00	124.80	84.32%	24	15	39
R16/806	LKD	W26/806	28.34	4.90	245.10	243.10	99.18%	23	16	39
		W27/806	5.18					0	0	0
		W28/806	10.17					0	8	8
		W29/806	29.93					1	0	1
R17/806	BEDROOM	W30/806	27.27	4.26	119.10	118.20	99.24%	N/A	N/A	N/A
R18/806	LKD	W31/806	8.84	1.30	281.50	209.40	74.39%	2	0	2
		W32/806	2.65					0	0	0
R19/806	BEDROOM	W33/806	27.08	3.20	92.40	88.00	95.24%	N/A	N/A	N/A
R20/806	BEDROOM	W34/806	18.44	2.25	152.40	122.10	80.12%	N/A	N/A	N/A
R21/806	LKD	W35/806	15.34	3.73	326.00	324.10	99.42%	9	1	10
		W36/806	15.18					3	0	3
		W37/806	5.67					0	0	0
		W38/806	35.33					3	0	3
R22/806	BEDROOM	W39/806	35.09	4.32	84.20	82.10	97.51%	N/A	N/A	N/A
R23/806	BEDROOM	W40/806	32.97	4.13	115.30	111.20	96.44%	N/A	N/A	N/A
R24/806	LKD	W41/806	16.09	2.23	211.80	202.70	95.70%	N/A	N/A	N/A
R25/806	BEDROOM	W42/806	5.36	3.61	142.30	140.30	98.59%	2	0	2
		W43/806	36.48					8	0	8
R26/806	BEDROOM	W44/806	35.35	5.01	124.50	121.40	97.51%	N/A	N/A	N/A
R27/806	BEDROOM	W45/806	16.76	3.76	112.60	111.80	99.29%	N/A	N/A	N/A
R28/806	LKD	W46/806	6.62	3.42	245.00	245.00	100.00%	3	1	4
		W47/806	37.31					8	0	8
R29/806	BEDROOM	W48/806	37.43	2.94	138.00	135.50	98.19%	N/A	N/A	N/A
R30/806	BEDROOM	W49/806	37.56	3.46	116.70	112.90	96.74%	N/A	N/A	N/A
R31/806	BEDROOM	W50/806	10.18	1.66	84.10	79.00	93.94%	N/A	N/A	N/A
R32/806	LKD	W51/806	14.53	2.06	290.50	266.60	91.77%	N/A	N/A	N/A
<b>7th Floor</b>										
R1/807	BEDROOM	W1/807	18.89	4.06	112.60	112.00	99.47%	11	8	19
R2/807	LKD	W2/807	12.67	3.14	245.40	244.50	99.63%	6	0	6
		W3/807	28.07					27	7	34
R3/807	LKD	W4/807	19.93	2.39	215.80	215.50	99.86%	12	9	21
R4/807	BEDROOM	W5/807	13.33	4.65	150.70	147.20	97.68%	6	0	6
		W6/807	28.00					27	7	34
R5/807	BEDROOM	W7/807	19.92	4.06	116.70	116.00	99.40%	12	9	21
R6/807	LKD	W8/807	13.36	3.14	250.30	249.50	99.68%	6	0	6
		W9/807	28.17					27	7	34
R7/807	LKD	W10/807	19.95	2.16	255.90	247.80	96.83%	12	9	21
R8/807	BEDROOM	W13/807	39.51	3.11	136.20	129.40	95.01%	34	15	49
R9/807	LKD	W14/807	39.51	5.20	236.10	235.60	99.79%	38	19	57
		W15/807	15.79					2	18	20
R10/807	BEDROOM	W16/807	13.30	3.96	129.60	128.60	99.23%	2	11	13
		W17/807	31.22					25	16	41
R11/807	BEDROOM	W18/807	30.06	2.24	148.00	129.00	87.16%	24	16	40
R12/807	LKD	W19/807	29.35	5.00	245.40	243.40	99.19%	25	16	41
		W20/807	5.57					0	0	0
		W21/807	10.67					0	9	9
		W22/807	30.55					1	0	1
R13/807	BEDROOM	W23/807	27.71	4.30	119.10	118.10	99.16%	N/A	N/A	N/A

Room/Floor	Room Use	Window	Daylight Distribution			%Sun				
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
R14/807	LKD	W24/807	9.07	1.61	225.40	179.90	79.81%	N/A	N/A	N/A
R15/807	BEDROOM	W25/807	2.77	3.35	118.40	108.80	91.89%	0	1	1
		W26/807	27.66					2	0	2
R16/807	BEDROOM	W27/807	18.91	2.72	119.00	101.30	85.13%	N/A	N/A	N/A
R17/807	LKD	W28/807	16.34	4.09	322.70	320.80	99.41%	9	1	10
		W29/807	15.31					3	0	3
		W30/807	5.85					0	0	0
		W31/807	35.73					3	0	3
R18/807	BEDROOM	W32/807	35.66	4.33	84.20	82.10	97.51%	N/A	N/A	N/A
R19/807	BEDROOM	W33/807	33.52	4.14	115.30	111.50	96.70%	N/A	N/A	N/A
R20/807	BEDROOM	W35/807	5.47	4.59	104.00	102.90	98.94%	2	0	2
		W36/807	36.74					8	0	8
R21/807	LKD	W34/807	12.28	1.71	244.60	219.30	89.66%	N/A	N/A	N/A
R22/807	BEDROOM	W37/807	36.91	4.58	132.00	124.10	94.02%	N/A	N/A	N/A
<b>8th Floor</b>										
R1/808	LKD	W1/808	19.57	1.96	271.40	223.00	82.17%	12	9	21
R2/808	BEDROOM	W2/808	13.04	4.69	148.20	146.40	98.79%	6	0	6
		W3/808	27.69					26	7	33
R3/808	BEDROOM	W4/808	19.92	4.06	116.70	116.00	99.40%	12	9	21
R4/808	LKD	W5/808	13.33	3.15	250.40	249.50	99.64%	6	0	6
		W6/808	28.43					27	7	34
R5/808	LKD	W7/808	19.95	2.20	250.70	242.50	96.73%	12	9	21
R6/808	BEDROOM	W10/808	39.52	3.12	136.20	129.40	95.01%	34	15	49
R7/808	LKD	W11/808	39.51	5.29	236.10	235.70	99.83%	38	19	57
		W12/808	16.39					2	18	20
R8/808	BEDROOM	W13/808	13.32	4.01	129.60	128.60	99.23%	2	11	13
		W14/808	32.13					26	16	42
R9/808	BEDROOM	W15/808	31.04	2.30	148.00	136.20	92.03%	25	16	41
R10/808	LKD	W16/808	30.38	5.12	245.40	243.40	99.19%	26	16	42
		W17/808	6.01					0	0	0
		W18/808	11.57					0	9	9
		W19/808	31.26					1	0	1
R11/808	BEDROOM	W20/808	28.22	4.33	119.10	118.10	99.16%	N/A	N/A	N/A
R12/808	LKD	W21/808	9.33	1.63	225.40	180.00	79.86%	N/A	N/A	N/A
R13/808	BEDROOM	W22/808	3.00	3.44	118.40	109.60	92.57%	0	2	2
		W23/808	28.81					2	0	2
R14/808	BEDROOM	W24/808	19.34	2.74	119.00	101.50	85.29%	N/A	N/A	N/A
R15/808	LKD	W25/808	17.84	3.44	377.30	375.30	99.47%	12	2	14
		W26/808	15.48					3	0	3
		W27/808	6.28					0	0	0
		W28/808	36.07					3	0	3
R16/808	BEDROOM	W29/808	36.21	4.23	84.70	81.20	95.87%	N/A	N/A	N/A
R17/808	BEDROOM	W30/808	36.36	6.12	185.30	181.60	98.00%	N/A	N/A	N/A
		W31/808	36.69					N/A	N/A	N/A
<b>9th Floor</b>										
R1/809	BEDROOM	W1/809	18.50	3.87	116.50	115.80	99.40%	10	8	18
R2/809	LKD	W2/809	12.28	3.16	250.30	249.50	99.68%	6	0	6
		W3/809	29.83					28	9	37
R3/809	LKD	W4/809	32.83	3.43	256.30	248.00	96.76%	32	10	42
R4/809	BEDROOM	W7/809	39.40	3.10	136.20	129.40	95.01%	34	15	49
R5/809	LKD	W8/809	39.40	5.20	236.10	235.70	99.83%	38	19	57
		W9/809	15.69					2	17	19
R6/809	BEDROOM	W10/809	12.41	3.98	129.60	128.60	99.23%	1	10	11
		W11/809	32.96					27	17	44
R7/809	BEDROOM	W12/809	31.97	2.35	148.00	140.50	94.93%	26	17	43

Room/Floor	Room Use	Window	Daylight Distribution					%Sun		
			%VSC	%ADF	Room Area sq ft	Proposed Area sq ft	Proposed % of Room Area	Summer	Winter	Total
R8/809	LKD	W13/809	31.37		245.40	243.40	99.19%	26	17	43
		W14/809	5.81	5.12				0	0	0
		W15/809	11.39					1	9	10
		W16/809	32.30					1	0	1
R9/809	BEDROOM	W17/809	29.06	4.35	119.10	118.20	99.24%	N/A	N/A	N/A
R10/809	LKD	W18/809	9.17	1.32	280.70	214.10	76.27%	2	0	2
		W19/809	3.36					0	0	0
R11/809	BEDROOM	W20/809	31.84	3.52	93.40	91.70	98.18%	N/A	N/A	N/A
R12/809	BEDROOM	W21/809	21.03	2.40	152.40	123.70	81.17%	N/A	N/A	N/A
R13/809	BEDROOM	W22/809	21.42	4.38	160.40	160.40	100.00%	19	6	25
		W23/809	14.94					3	0	3
R14/809	LKD	W24/809	6.33	2.10	262.40	261.30	99.58%	0	1	1
		W25/809	36.18					3	0	3
<b>10th Floor</b>										
R1/810	BEDROOM	W1/810	39.56	4.57	116.10	113.60	97.85%	38	18	56
R2/810	BEDROOM	W2/810	39.55	4.54	113.00	105.90	93.72%	38	18	56
R3/810	LKD	W3/810	39.54	7.03	255.50	231.10	90.45%	38	20	58
		W4/810	34.45					30	21	51
R4/810	LKD	W5/810	33.65	5.86	234.90	234.40	99.79%	29	22	51
R5/810	BEDROOM	W6/810	32.50	7.35	124.40	123.70	99.44%	27	18	45
		W7/810	33.08					1	0	1
R6/810	BEDROOM	W8/810	29.44	3.58	91.10	81.00	88.91%	N/A	N/A	N/A

# Contact Details

---

**Enquiries**

Gregory Francis  
020 7911 2705  
07908 664 649  
[gregory.francis@avisonyoung.com](mailto:gregory.francis@avisonyoung.com)

**Visit us online**

[avisonyoung.co.uk](http://avisonyoung.co.uk)

---

**Avison Young**

65 Gresham Street, London EC2V 7NQ  
Avison Young is the trading name of GVA Grimley Limited  
© 2019 GVA Grimley Limited